

## **Certificate of Compliance**

No. LVD21-8560

About the Low Voltage Directive 2014/35/EU

Applicant: Zhejiang Chint Electrics Co., Ltd.

No. 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing City, Zhejiang Province, 325603, P. R. China

Product/Material: Relay

Trade Mark: CHNT

Model/Type: NXJ Series

Rated Specification: Contact loads: 10A 250VAC/30VDC(2ZH),

5A 250VAC/30VDC(2Z,3Z), 3A 250VAC/30VDC(4Z), Coil voltage: 5VDC, 6VDC, 12VDC, 24VDC, 36VDC, 48VDC, 110VDC, 127VDC, 220VDC 0.9W, 6VAC, 12VAC, 24VAC, 36VAC, 48VAC, 110VAC,

127VAC, 220VAC, 230VAC, 240VAC, 380VAC, 400VAC,

415VAC 1.8VA, Electrical endurance: 20000 cycle,

Mechanical endurance: 50000 cycle, Ambient temperature: -25°C~55°C; RT I

Tested According to:

EN 61810-1:2015

Referred to the Technical Report: RZCE2021-0036

This certificate of conformity is based on an evaluation of a tested sample of the product mentioned above. It does not imply assessment of series-production of the product. The applicant should hold the whole technical report at the disposal of the competent authority.

Provided it is also confirmed with any other EU directives, the manufacturer or its authorized European representative may draw up an EC/EEA Declaration of Conformity and affix the CE-mark shown below to each conforming product.





中国认可 国际互认 检测 TESTING CNAST 0095



Signed by:

Nichogiang

Xie Haojiang

Date of Issue: May. 25, 2021

Vkan Certification & Testing Co., Ltd.

No.3, Tiantaiyi Road, Kaitai Avenue, Science City, Guangzhou, 510663, P. R. China Tel.: +86-20-32293888, Fax: +86-20-32293889.E-mail: office@cvc.org.cn

www.cvc.org.cn