



## VERIFICATION OF COMPLIANCE

No.: LVD SHES160300197801ITC

Applicant: Zhejiang CHINT Instrument & Meter Co., Ltd  
Wenzhou Bridge Industrial Zone, Yueqing, Wenzhou, Zhejiang,  
P.R. China

Manufacturer: Zhejiang CHINT Instrument & Meter Co., Ltd  
Wenzhou Bridge Industrial Zone, Yueqing, Wenzhou, Zhejiang,  
P.R. China

Product Name: AC Voltmeter

Product Description: AC Voltmeter

Model No.: NP48-V, NP72-V, NP96-V

Rating: Max. measurement range:  
Direct connection method: 500 V max.  
Via transformer connection method: 450 kA max.

Protection against Electric Shock: N/A

Additional Information (if any): This verification replaces SHES130400131301TXC

Sufficient samples of the product have been tested and found to be in conformity with

Test Standard: EN 61010-1: 2010  
as shown in the

Test Report Number(s): SHES160300197801

This Verification of LVD Compliance has been granted to the applicant based on the results of tests, performed by Laboratory of SGS-CSTC Standards Technical Services Co., Ltd. on sample of the above-mentioned product in accordance with the provisions of the relevant specific standards and the Low Voltage Directive 2014/35/EU. The CE marking as shown below can be affixed, under the responsibility of the manufacturer, after completion of an EC Declaration of Conformity and compliance with all relevant EC Directives. The affixing of the CE marking presumes in addition that the conditions in annexes III and IV of the Directive are fulfilled.

  
Andrew Zhai  
Laboratory Technical Manager  
SGS-CSTC



Copyright of this verification is owned by SGS-CSTC Standards Technical Services Co., Ltd. and may not be reproduced other than in full and with the prior approval of the General Manager. This verification is subjected to the governance of the General Conditions of Services, printed overleaf.

Member of SGS Group (Société Générale de Surveillance)